

Residential Sprinkler Requirements NFPA 13D

- ❖ **1 ½ inch (ID) lead-in required on Municipal water supply**
- ❖ **Double check valve**
- ❖ **Exterior audio/visual device, shall be connected to water flow switch at location approved by Fire Official**
- ❖ **Interior 6 inch bell mounted to supply duct**
- ❖ **Attached garages to be covered by sprinklers**
- ❖ **Suppression system not required to be monitored by Fire Department Dispatch Center**
- ❖ **Steel, copper, CPVC plastic piping acceptable for residential suppression**
- ❖ **Electrical heating wire or tape prohibited**
- ❖ **Attic and exterior walls to be avoided**
- ❖ **All electrical installations to comply with local ordinances**

**Sprinkler systems within the Fire Protection District shall be approved
by a Fire Official.**

**Al Wiesneth
Huntley Fire Department
Fire Marshal**

**Ernie Link
Huntley Fire Department
Fire Prevention Officer**